




**TOWN OF GREENBURGH  
DEPARTMENT OF PUBLIC WORKS**

177 Hillside Avenue, White Plains, NY 10607  
Office: (914) 989-1580 Fax: (914) 993-1639  
Web Site: www.greenburghny.com



Greenburgh Recycles

VICTOR G. CAROSI, P.E.  
Commissioner

RICHARD C. FON  
Superintendent of Public Works

**NOTICE TO BIDDERS  
2017 ANNUAL BID FOR WATER  
MATERIALS & SUPPLIES**

**NOTICE IS HEREBY GIVEN** that sealed bids will be received by the Town Clerk of the Town of Greenburgh, until the deadline of **11:00 a.m. on November 22, 2016**, at the Office of the Town Clerk, 177 Hillside Avenue, Greenburgh, New York 10607, at which time and place all received sealed bids will be publicly opened and read aloud for the furnishing and/or installing of the following:

**WATER & SEWER DEPARTMENT**

**FIRE HYDRANTS and PARTS**

1. Fire Hydrants
2. Fire Hydrant Extension Kit
3. Fire Hydrant Safety Flange Repair Kits
4. Replacement Fire Hydrant

**BRASS VALVES and FITTINGS**

5. Corporation Stop Valve
6. Corporation Stop Valve/Heavy Duty
7. Curb Shut-Off Valve
8. Union
9. Straight Coupling

**CLAMPS, COUPLINGS, ADAPTERS & SADDLES**

10. Full Circle Single Band
11. Straight Coupling
12. Flanged Coupling Adapters
13. Service Saddles

**GATE VALVES**

14. Gate Valves Resilient Wedge

**WATER METERS - NEPTUNE**

15. T-10
16. True/Flow
17. Protectus III Fire Meters
18. Water Meter parts

**WATER METER PITS**

19. Meter Pits



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

No bids will received will be considered after the time stated above. Specifications and Bid Proposal Forms may be obtained on the Town's website, [www.greenburghny.com](http://www.greenburghny.com), [www.empirestatebid.com](http://www.empirestatebid.com) and at the Office of the Commissioner of Public Works after October 27, 2016. To be considered, all bids must be submitted in a sealed envelope bearing the name and address of the bidder and clearly marked "**ANNUAL BID FOR WATER MATERIALS & SUPPLIES/GREENBURGH WATER DEPARTMENT/2017**".

Please note bidders must submit statement of Non-Collusion in accordance with Section 103-D of the Municipal Law. Omission of this item will result in rejection of the bid.

The Town Board of the Town of Greenburgh reserves the right to accept or reject any or all bids and to waive any informalities at their discretion, and to award contracts in a manner deemed to be in the best interests of the Town of Greenburgh even if such award is to other than the lowest bidder. All questions shall be directed to the Commissioner of Public Works at (914) 989-1575.

*Judith A. Beville*  
*Town Clerk*  
*Town of Greenburgh*

*Dates of Publication: October 27, 2016*



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**TOWN OF GREENBURGH  
DEPARTMENT OF PUBLIC WORKS**

<b>Category</b>	<b>Page</b>
Notice to Bidders	i-ii
Information For Bidders	1-2
Water & Sewer Items & Bid Proposal Forms	3-25
<b>FIRE HYDRANTS and PARTS</b>	
1. Fire Hydrants	3
2. Fire Hydrant Extension Kit	3
3. Fire Hydrant Safety Flange Repair Kits	4
4. Replacement Fire Hydrant	4
<b>BRASS VALVES and FITTINGS</b>	
5. Corporation Stop Valve	7
6. Corporation Stop Valve/Heavy Duty	7
7. Curb Shut-Off Valve	7
8. Union	7
9. Straight Coupling	7
<b>CLAMPS, COUPLINGS, ADAPTERS &amp; SADDLES</b>	
10. Full Circle Single Band	11
11. Straight Coupling	11
12. Flanged Coupling Adapters	11
13. Service Saddles	11
<b>GATE VALVES</b>	
14. Gate Valves Resilient Wedge	17
<b>WATER METERS - NEPTUNE</b>	
15. T-10	19
16. True/Flow	19
17. Protectus III Fire Meters	19
18. Water Meter parts	19
<b>WATER METER PITS</b>	
19. Meter Pits	22
Bid Proposal	23
Non-Collusive Bidding Certificate	25



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**INFORMATION FOR BIDDERS**

**Delivery Locations**

All of the materials as specified in these detailed specifications shall be delivered Freight on Board FOB, (no additional shipping charges) to the Water and Sewer Department facilities at:

Town of Greenburgh  
Water and Sewer Department  
181 Knollwood Road  
White Plains, NY 10607

Town of Greenburgh  
Rumbrook Pump Station  
Rumbrook Park  
700 Dobbs Ferry Road  
White Plains, NY 10607

or to at any point in the Town of Greenburgh as may be directed by the Commissioner of Public Works, and in any quantity equal to or greater than the minimum specified. All material supplied shall conform to the standard specifications of the American Water Works Association, as well as all applicable ASTM and Federal Specifications, as appropriate.

**No Sales Tax Paid**

All bids submitted shall be exclusive of any sales, excise or other taxes, for delivery to a tax exempt municipality. Bids shall be valid for all orders placed during the calendar year. Where a firm price cannot be held for the year, a ninety (90) day bid should be submitted and clearly noted on the bid for the item.

**Rights to Purchase Reserved**

The Town of Greenburgh reserves the right to purchase the same or similar materials from the State of New York Office of General Services at the current New York State Bid Price for any of the items bid within this contract, without notice to the vendor awarded the Town bid if it is deemed appropriate and in the best interests of the Town by the Town's Commissioner of Public Works and the bidder shall have no recourse to the Town for any lost profit resulting from this action.

**Compliance with Specifications**

All bids are to be submitted in strict conformance with the itemized specifications and for delivery within the time limit as stated for the specified time. All suppliers submitting bids on items in non-conformance with the specifications or delivery time as stated must submit them on separate sheets of paper, clearly stating the variance between their bid and the specifications and with the paper clearly indicating the bidder. The Town reserves the right to reject any item bid not in compliance with the specifications. Additional information on any of the items as given in the detailed specifications may be secured from the office of the Commissioner of Public Works.



## 2017 ANNUAL BID FOR WATER MATERIALS & SUPPLIES

### **Liquidated Damages**

Whenever a delivery time in days is specified herein, it shall be assumed to refer to the number of consecutive calendar days from receipt of order. In the event of delay in delivery for whatever reason, whether it is due to the bidder's action or otherwise, the successful bidder agrees to have the amount of ten dollars (\$10.00) deducted for each material each and every calendar day that delivery is so delayed. This deduction is to be considered not as a penalty, but as liquidated damages which the Town will suffer by reason of such delay or default.

### **Bidders Certification**

A bidder certifies, by submitting a bid, that the business is current in the payment of all franchise and other taxes due the State of New York.

Bidder further certifies that no officer, director or stockholder (if less than 10 stockholders) of the bidder is an officer or employee of the Town or a relative of any such Town officer or employee. If such officer, director or stockholder does exist, their names and relationships should be disclosed to the Town.

The successful bidder may be asked to provide the Town with a certificate issued by the Secretary of the State that the Corporation is duly authorized to do business within the State of New York and is presently in good standing. If the entity to whom the bid is awarded is not a corporation, it would be required that the entity's certificate of doing business, which should be on file in the County Clerk's Office, be provided. (This would also hold true in the case of joint ventures, which would be required to disclose the underlying entities which make up the joint venture and to supply the requisite certificate of doing business of each such entity.)

### **Bid Award Categories**

Yearly quantities where listed, are only an estimate, not a guarantee of quantity to be purchased. Bid items are divided into general categories. **To be considered a bidder must bid all items within the category.** Award will be made per category for the items within that category. A bidder may bid on all categories, but an award will be made only to that bidder that provides the lowest cost, meeting the specifications to a **complete** category of items, unless otherwise deemed to be in the best interest of the Town. The Town reserves all rights to make determinations to the bid deemed the best interest of the Town.

All bid prices must be submitted on the attached bid forms. Faxed or emailed bids are not accepted.

### **Surcharges Not Accepted**

Surcharges including fuels, shipping, delivery, handling or any other additional charge beyond the unit price bid will not be accepted.



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**FIRE HYDRANTS and PARTS**

**Item 1. FIRE HYDRANTS** – Hydrants supplied shall be Mueller Super Centurion 250 only and shall conform to ANSI/AWWA Specification C502, UL 246 and FM 1510 specifications, latest revision. Bids shall be submitted for a bury length of 4' - 0".

Hydrants shall be provided with two (2) 2½" hose outlet nozzles and one (1) 4½" pumper outlet nozzle. All outlet nozzle threads shall conform to National American Standard Fire Hose Coupling Screw Threads, in accordance with NFPA 1963. Hydrant shall have nominal valve opening of 5¼". Hydrant shall have a 6" diameter connection by means of mechanical joint, and come complete with a "mega lug" or equal accessory kit and include gasket, bolts, nuts glands, flanges. The operating nut shall be 1½" Pentagon, open left (counter clockwise). Hydrants shall be painted with the standard prime coats and a final coat of high gloss hydrant yellow for barrel section and high gloss hydrant green for bonnet (top) section. Shutoff shall be compression type. Hydrants shall be provided with the "traffic feature", allowing a connecting safety flange to break readily near ground level if struck, without permanent damage to the permanent barrel part.

All internal ferrous metal surfaces of the hydrant shoe or base shall be fully coated, holiday free, to a minimum thickness of 4 mils with a two-part thermo setting epoxy coating. Said coating shall be non-toxic, impart no taste to the water, and protect all surfaces from corrosion and prevent build-up of scale tuberculation.

Catalog sheets, shop drawings, and any special details or instructions shall be furnished with the bids to identify the exact model being submitted by each bidder. An affidavit of compliance and records of standard tests shall be furnished upon delivery.

Bids are requested for hydrants furnished with (A) mechanical joint *Megalug* retainer glands as manufactured by EBAA Iron, Inc. or equal on the inlets AND (B) furnished with flanged inlets. Delivery shall be FOB to the delivery point identified in the instructions to bidders. The bid prices shall include all accessories necessary for the complete installation of the hydrant. Separate prices for accessories will not be accepted.

**Item 2. FIRE HYDRANT EXTENSION KIT** – Bid prices shall be submitted for Mueller A-320 extension kits, for use on 5¼" main valve opening hydrants. Bids are requested for extension lengths: 0'-6", 1'-0", 1'-6", 2'-0" and 2'-6".



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**Item 3. FIRE HYDRANT SAFETY FLANGE REPAIR KITS** – Fire Hydrant Safety Flange Repair Kits supplied shall be Mueller # A301 and Clow Valve Kit R1620653 (Clow Medallion) for use with 5¼” hydrant main valve opening. Please quote both items.

**Item 4. REPLACEMENT FIRE HYDRANT** - Shall be a direct replacement for old “R.D.Wood/Mathews Spin In” type hydrants as manufactured by the Mueller Company, or approved equal, and conform in all other respects as to the Mueller Super Centurion Hydrant of Item 1. This replacement hydrant shall “screw in” to the existing “shoe” of the old hydrant once the upper portion of the old hydrant is “un-screwed”; this process shall be accomplished without the need to dig around the hydrant to be replaced. Future repairs and/or replacements of the main washer must be able to be accomplished internally through the “new” replacement hydrant, and shall not require any digging or removal of the hydrant. The new replacement hydrants shall be equipped with a “break-away” type flange similar to the type supplied in Item 1.

Prices are requested for a 4’, 4½’, 5’ and 5½’ depth of bury.

*Complete bid form next page*



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**FIRE HYDRANTS**

*MUELLER SUPER CENTURIAN*

<b>Item No.</b>	<b>Description</b>	<b>Est. Qty.</b>	<b>Unit</b>	<b>Unit Price (in words)</b>	<b>Unit Price (in numbers)</b>	<b>Extension Est. Qty. x Unit Price (in numbers)</b>
1	Mueller Super Centurion Hydrant 5¼"	5	each			
2a	Extension Kit 6"	5	each			
2b	Extension Kit 1'-0"	5	each			
2c	Extension Kit 1'-6"	5	each			
2d	Extension Kit 2'-0"	5	each			
2e	Extension Kit 2'-6"	5	each			
3a	Flange Safety Repair Kit Mueller # A301	5	each			
3b	Flange Safety Repair Kit Clow R1620653	5	each			



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

4a	Screw type replacement hydrant 4'-0"	5	each			
4b	Screw type replacement hydrant 4'-6"	5	each			
4c	Screw type replacement hydrant 5'-0"	5	each			
4d	Screw type replacement hydrant 5'-6"	5	each			

**Note to supplier** – When considering FOB pricing, the Town will commit to order hydrants in groups of five (5) i.e., Any order for hydrants will be for five (5) or more in total.

**TOTAL BID:** \_\_\_\_\_

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name*
\_\_\_\_\_
\_\_\_\_\_  
*Signed*
*Date*

Company: \_\_\_\_\_

(Seal of Corporation)

\_\_\_\_\_

\_\_\_\_\_

( ) \_\_\_\_\_ ( ) \_\_\_\_\_

*Phone* *Fax*

*Complete Acknowledgements at last page* Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BRASS FITTINGS**

All fittings must meet new Lead Free Brass Law in accordance with ANSI/WSF60-HSF61 or latest revision.

**Item 5. CORPORATION STOP VALVE** – Mueller “110” Compression Connection, Cat. #B-25008, or equal. Supplied valves shall have AWWA taper thread for connecting to tapped water main and be compatible with the Mueller Pipe Tapping Machine. The service connection end of the coupling shall be compression type for use with type “K” copper tubing. Corporation shall be straight through type and include ring for type “K” copper. Must meet or exceed ANSI/AWWA C-800-05 or latest revision.

**Item 6. CORPORATION STOP VALVE/HEAVY DUTY** – Mueller “110” compression Connection, Cat. #B-25008, or equal - heavy duty. Must meet or exceed ANSI/AWWA C-800-05 or latest revision. Must meet or exceed ANSI/AWWA C-800-05 or latest revision. Must meet or exceed ANSI/AWWA C-800-05 or latest revision.

**Item 7. CURB SHUT-OFF VALVE** - Mueller “Mark II Oriseal” with Mueller “110” Conductive Compression Connection, Cat. #H-15209 or equal ¼” Turn shut-off with a stop at full off and full on. Suitable for use with a permanent valve rod connected to key. Conductive compression type connections shall be provided at inlet and outlet connections. Compression Ring is included. Must meet or exceed ANSI/AWWA C-800-05 or latest revision. Provided with check stop and no drain.

**Item 8. UNION** - Mueller #H-15403, or equal. Straight three part union Mueller "110" conductive compression connection for copper tubing sized O.D. tubing both ends. Must meet or exceed ANSI/AWWA C-800-05 or latest revision.

**Item 9. STRAIGHT COUPLING** - Straight adapter Mueller "110" Compression Connection for copper tubing size O.D. tubing x Female Iron Pipe thread. Mueller #H-15451, or equal. Must meet or exceed ANSI/AWWA C-800-05 or latest revision.



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**BRASS FITTINGS**

Item No.	Description	Est Qty.	Unit	Unit Price (in words)	Unit Price (in numbers)	Extension Est. Qty. x Unit Price (in numbers)
5a	Corporation Stop Valve ¾"	1	each			
5b	Corporation Stop Valve 1"	1	each			
6a	Corporation Stop Valve 1½"	1	each			
6b	Corporation Stop Valve 2"	1	each			
7a	Curb-Stop ¾"	1	each			
7b	Curb-Stop 1"	1	each			
7c	Curb-Stop 1½"	1	each			
7d	Curb-Stop 2"	1	each			
8a	Union ¾"	1	each			
8b	Union ¾" x 1"	1	each			



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**BRASS FITTINGS**

*Continued*

Item No.	Description	Est Qty.	Unit	Unit Price (in words)	Unit Price (in numbers)	Extension Est. Qty. x Unit Price (in numbers)
8c	Union 1"	1	each			
8d	Union 1 1/4"	1	each			
8e	Union 1 1/2"	1	each			
8f	Union 2"	1	each			
9a	Straight Coupling 3/4"	1	each			
9b	Straight Coupling 1"	1	each			
9c	Straight Coupling 1 1/2"	1	each			
9d	Straight Coupling 2"	1	each			

**TOTAL BID:** \_\_\_\_\_

*Complete next page*





2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

## Clamps, Couplings, Adapters and Saddles

**Item 10. FULL CIRCLE CLAMPS - SINGLE BAND** – “Smith Blair 226” , or “Power Seal 3121” or equal, full circle single band coupling for repairing full circumferential breaks, holes, cracks or other types of damage to water mains - cast iron, ductile iron, steel, asbestos cement, copper, aluminum, plastic, fiberglass. Must have built in O.D. range enabling clamp to fit several pipe outside diameters within nominal pipe size range. Must have lap type gasket with molded ends for efficient equalized sealing at the lap joint on any pipe within clamps range. Must have stainless steel bridge plate preventing wrinkling in lug area and providing even gasket pressure around full circumference of pipe. Must have stainless steel band for necessary corrosion resistance. Bolts and nuts must be Type 304, stainless steel, or approved equal.

**Item 11. STRAIGHT COUPLING** – “Smith-Blair OMNI 441” or “Power Seal 3501”, or equal, in accordance with AWWA C219. Sleeves and follower flanges to be Ductile Iron per ASTM A536/AWWA C219. Gaskets to be 100% new Rubber or Nitrile (Buna N) certified to NSF/ANSI 61G. Bolts and Nuts to be high strength #304 stainless steel. Coupling finish to be Fusion-Bonded Epoxy.

**Item 12. FLANGED COUPLING ADAPTERS** – “Smith Blair 912”, or equal, cast flanged coupling adapter, per AWWA C219. Shall include ductile iron “Tee Bolt” type of connecting bolts, and include all gaskets and high strength #304 Stainless steel nuts and bolts.

**Item 13. SERVICE SADDLES** - “Smith Blair #317”, or equal. Shall be certified NSF 61 and 372. AWWA C800. Shall include Type 304 stainless steel straps, nuts and bolts. ASTM A536 Ductile Iron body, Nitrile (Buna-N), NSF 61 listed gasket. Taps shall have CC thread. All sizes to have 1½” and 2” outlets with c.c. thread.

Complete bid forms, following pages



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**FULL CIRCLE CLAMPS - SINGLE BAND**

Smith Blair 226 or Power Seal 3121

Item No.	Nominal Pipe Size	OD Range (Inches)	Clamp Width	Qty.	Unit	Unit Price
10a	3"	3.73 -4.00	12½"	1	each	
10b	4"	4.74 -5.14	12½"	1	each	
10c	6"	6.84 -7.24	12½"	1	each	
10d	8"	8.99 -9.3	15"	1	each	
10e	10"	11.04 -11.44	15"	1	each	
10f	12"	13.10-13.50	15"	1	each	

**TOTAL BID:** \_\_\_\_\_

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name* *Signed* *Date*

Company: \_\_\_\_\_

(Seal of Corporation) \_\_\_\_\_  
*Street*

\_\_\_\_\_  
*City, State, Zip*

*Complete Acknowledgements at last page*

( ) \_\_\_\_\_ ( ) \_\_\_\_\_  
*Phone Fax*

Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**  
**STRAIGHT COUPLING**

Smith-Blair OMNI 441 or Power Seal 3501

Item No.	Nominal Pipe Size	OD Range End 1 (Inches)	OD Range End 2 (Inches)	Sleeve Length	Qty.	Unit	Unit Price
11a	4"	4.80-5.10	<i>as ordered</i>	6-8½"	1	each	
11b	6"	6.90-7.22	<i>as ordered</i>	6-8½"	1	each	
11c	8"	9.05-9.45	<i>as ordered</i>	6-9½"	1	each	
11d	10"	11.10-11.60	<i>as ordered</i>	6-9½"	1	each	
11e	12"	13.20-13.50	<i>as ordered</i>	6-9½"	1	each	

**TOTAL BID:** \_\_\_\_\_

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name* *Signed* *Date*

Company: \_\_\_\_\_

(Seal of Corporation) \_\_\_\_\_  
*Street*

\_\_\_\_\_  
*City, State, Zip*

*Complete Acknowledgements at last page*

( ) \_\_\_\_\_ ( ) \_\_\_\_\_  
*Phone Fax*

Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**  
**FLANGED COUPLING ADAPTERS**

Smith Blair 317, or equal

Item No.	Nominal Pipe Size	OD Range (Inches)	Qty.	Unit	Unit Price
12a	3"	<i>as ordered</i>	1	each	
12b	4"	<i>as ordered</i>	1	each	
12c	6"	<i>as ordered</i>	1	each	
12d	8"	<i>as ordered</i>	1	each	
12e	10"	<i>as ordered</i>	1	each	
12f	12"	<i>as ordered</i>	1	each	

**TOTAL BID:** \_\_\_\_\_

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name* *Signed* *Date*

Company: \_\_\_\_\_

(Seal of Corporation) \_\_\_\_\_  
*Street*

\_\_\_\_\_  
*City, State, Zip*

*Complete Acknowledgements at last page*

( ) \_\_\_\_\_ ( ) \_\_\_\_\_  
*Phone Fax*

Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**  
**SERVICE SADDLES**

Smith Blair 912, or equal

Item No.	Nominal Pipe Size	Tap Size CC Thread	Qty.	Unit	Unit Price
13a	4"	1½"	1	each	
13b	6"	1½"	1	each	
13c	8"	1½"	1	each	
13d	10"	1½"	1	each	
13e	12"	1½"	1	each	
13f	4"	2"	1	each	
13g	6"	2"	1	each	
13h	8"	2"	1	each	
13i	10"	2"	1	each	
13j	12"	2"	1	each	

**TOTAL BID:** \_\_\_\_\_





2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**Item 14. GATE VALVES - RESILIENT WEDGE** – (Mueller or equal) shall conform to AWWA Specification C-515 latest revision, be UL Listed and FM Approved for the required conditions. Size, type and quantity of valves to be furnished as specified below.

Unless otherwise specified at time of purchase, valves shall be provided for vertical mounting position in line, non-rising stem and nut operated. Catalog sheets, shop drawings, and any special details or instructions shall be furnished by the manufacturer at the time of bidding, sufficient to identify the model being bid upon. Affidavit of compliance and record of standard test shall be furnished at time of delivery. Inside bore of valve shall be smooth with no grooves, recesses or channels. All surfaces shall be fusion bonded epoxy coating, complying with ANSI/AWWA C550. Coating shall be a minimum thickness of 3-4 mils.

Valve shall be supplied complete with all related nuts, bolts and gaskets, two of which should be anti-rotation bolts per kit. Two inch square wrench nut shall turn left to open. Type of Stem seal shall have a permanent lubricant sealed between the two O-rings.

All valves shall be manufactured in the United States by a firm which shall have been in the business of manufacturing valves for a period of at least 10 years, and replacement parts shall be readily available at this time. The manufacturer shall further guarantee to keep a stock of replacement parts available for a period of 10 years from date of delivery. Tapping valves shall be able to pass full size cutters.

Bids are requested for valves: (MJ) by (MJ) mechanical joint by mechanical joint ends with retaining bolts and glands including two *Megalug* retaining gland kits.

Complete bid forms, following pages



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**GATE VALVES - RESILIENT WEDGE**

Item No.	Nominal Pipe Size	Qty.	Unit	Unit Price
14a	4"	1	each	
14b	6"	1	each	
14c	8"	1	each	
14d	10"	1	each	
14e	12"	1	each	
14f	16"	1	each	

**TOTAL BID:** \_\_\_\_\_

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name* *Signed* *Date*

Company: \_\_\_\_\_

(Seal of Corporation) \_\_\_\_\_  
*Street*

\_\_\_\_\_  
*City, State, Zip*

*Complete Acknowledgements at last page*

(\_\_\_\_) \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_  
*Phone Fax*

Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**Item 15-18. WATER METERS** - Shall be as manufactured by Neptune Technology Group. All shall be supplied with E-Coder 450 RF registers – read in gallon and for use in submerged or “pit” conditions. Must meet or exceed AWWA C-700 thru C-707 depending on the meter requested, latest revisions for cold water meters.

Bids are requested for “Across the Board” Percent (%) Discount off the current list prices Neptune Technology Meters for pit applications to be supplied with (50) feet of wire. Meter registers and/or remotes must meet or exceed AWWA C-707- 05 or latest version.

IN ORDER FOR BID TO BE CONSIDERED A COPY OF THE LIST PRICES MUST BE SUBMITTED AT TIME OF BID.

Meters included are: Positive displacement, Compound, turbo, and Protectus.

METER SIZING:

**Item 15** T-10, 5/8” x 3/4” ; 3/4” ; 1” ; 1 1/2” and 2”

**Item 16** True/Flo Compound Meter in sizes 3”, 4” and 6”

**Item 17** Protectus III Fire Service Meter S (Stainless Steel) in sizes 4”, 6”, 8” and 10”  
All with E-Coder 450 RF Registers

**Item 18** MIU’s (Meter Interface Unit) for the Neptune 450RF meter reading system

**Meter flanges to be supplied in following sizes: 1 1/2” and 2” bronze companion flanges and shall include steel bolts, brass nuts and full faced gaskets.**

Bidder must submit with a bid form, a current Neptune Technology Meter catalog and list prices.

DELIVERY TO BE MADE WITHIN THIRTY DAYS FROM RECEIPT OF ORDER.

Delivery is to be made to the Town of Greenburgh, Water and Sewer Department, 181 Knollwood Road, White Plains, NY 10607.

**Item 19. WATER METER PARTS:** Shall be as manufactured by Neptune Technology Group. Bids are requested for an “Across the Board” Percent (%) Discount on the current List Price of Neptune Technology and shall include MIU’s (Meter Interface Units) for the 450RF meter reading system and receptacles for all meters. Bidder must submit on bid form, a current Neptune Technology Meter Part catalog and list price for all parts.

DELIVERY TO BE MADE WITHIN THIRTY DAYS FROM RECEIPT OF ORDER.

Delivery is to be made to the Town of Greenburgh, Water and Sewer Department, 181 Knollwood Road, White Plains, NY.



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**BID FORM**

**NEPTUNE WATER METERS**

All with E-Coder 450 RF Registers, gallon registers

Item No.	Meter Style	Meter Size	Qty.	% off List	Unit Price
15a	T-10	5/8"	1		
15b	T-10	3/4"	1		
15c	T-10	1"	1		
15d	T-10	1½"	1		
15e	T-10	2"	1		
16a	True Flow Compound	3"	1		
16b	True Flow Compound	4"	1		
16c	True Flow Compound	6"	1		
17a	Protectus III - Fire	4"	1		
17b	Protectus III - Fire	6"	1		
17c	Protectus III - Fire	8"	1		
17d	Protectus III - Fire	10"	1		
18	450 RF MIU	One Size	1		
19	450MIU ENHANCED	One Size	1		



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

20	ENHANCED ANTEENNA ONLY	One Size	1		
21	REGISTERS	All Sizes	1		





2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**Item 21. WATER METER PITS:** Water meter pits shall be manufactured by Mueller for use with ¾"-2" diameter water meters. Pits shall include insulation pad, cast iron frame and cast iron locking cover. A price for each of the two (2) types of meter pits, complete shall be given for the following:

- A. "Ez-Vault" meter setter, 48" high x 27" diameter for 1½ and 2" meters. Price shall include optional insulation pad, flat lid with side mounted standard pentagon nut locking cover. Bid shall be for complete unit.
- B. "Thermal-Coil" meter box, 48" high x 18" diameter for ¾" and 1" meters. Price shall include optional insulation pad, flat lid with side mounted standard pentagon nut locking cover. Bid shall be for complete unit.

**BID FORM WATER METER PITS**

Item No.	Meter Pit Style	Qty.	Unit	Unit Price
19a	EZ Vault	1	each	
19b	Thermal-Coil	1	each	

THE ABOVE PROPOSAL IS SUBMITTED BY:

By: \_\_\_\_\_  
*Print Name*
\_\_\_\_\_
*Signed*
\_\_\_\_\_
*Date*

Company: \_\_\_\_\_  
 \_\_\_\_\_

(Seal of Corporation) \_\_\_\_\_  
*Street*

\_\_\_\_\_

*Complete Acknowledgements at last page*

(\_\_\_\_) \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_  
*Phone*
*Fax*  
 Email: \_\_\_\_\_



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**Bid Proposal Form**

**2017 ANNUAL BID FOR WATER MATERIALS & SUPPLIES**

The Town of Greenburgh  
Office of the Town Clerk  
177 Hillside Avenue  
Greenburgh, New York 10607

1. I/We hereby declare that I/We have carefully examined the Notice to Bidders, the Specifications and Requirements and documents for the above entitled materials and supplies.
2. I/We do hereby offer and agree to furnish all materials, to fully and faithfully perform and execute all work in the above titled matter in accordance with the related Specifications and Requirements. I/We will furnish all labor, tools, implements, transportations and materials necessary and proper for the purpose(s) and for the price(s) set forth on the bid forms.
3. I/We do hereby declare that the prices so stated cover all expenses of every kind incidental to the completion of said work, and the contract therefore, including all claims that may arise through damages or any other cause whatsoever.
4. I/We do hereby agree that I/We will execute a contract therefore, containing all terms, conditions, provisions and covenants necessary to complete the work according to the Specifications and Requirements on written notice by the Town of Greenburgh that the contract has been awarded by the Town.
5. I/We hereby affirm that by submission of this Bid, each bidder and each person signing on behalf of any Bidder certifies, and in the case of a joint bid each party certifies as to its organization, under the penalty of perjury, that to the best of knowledge and belief:
  - a. The prices in this Bid have been arrived at independently without collusion, consultation, communication or agreement, for the purpose of restricting competition, as to any matter relating to such prices with any other Bidder or with any competitor; and
  - b. Unless otherwise required by law, the prices which have been quoted in this Bid have not been knowingly disclosed by the Bidder and will not knowingly be disclosed by the Bidder prior to opening, directly or indirectly, to any other Bidder or to any competitor; and
  - c. No attempt has been made or will be made by the Bidder to induce any person, partnership or corporation to submit or not submit a Bid for the purpose of restricting competition.
  - d. No member of the Town Board, or officer, or employee of the Town of Greenburgh, or person whose salary is payable in whole or in part by the Town is or



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

- shall become interested as a contracting party, partner, stockholder, surety, or otherwise, in this Bid or in the performance of this Contract, or in the supplies, materials, or equipment and work or labor to which it relates, or in any portion of the profits thereof.
6. I/We hereby agree that this proposal is a firm Bid and shall remain in effect for a period of at least forty five (45) calendar days from the Bid-opening subject to extension on mutual agreement.
  7. I/We declare that if this is a Corporate Bid I/We have been duly authorized to act as the Signatory on this proposal on behalf of this Corporation.
  8. I/We affirm, under penalty of perjury, that all statements in this proposal are true and correct.
  9. I/We hereby agree that I/We accept the prices set forth on the following pages for the various items of work.
  10. All work shall be completed as specified within the Specifications and Requirements, which are understood to include all documents attached hereto.

---

Legal Name of Person, Firm or Corporation

---

Signed

---

Title



2017 ANNUAL BID FOR  
WATER MATERIALS & SUPPLIES

**NON-COLLUSIVE BIDDING CERTIFICATE**

Made pursuant to Section 103-d of the New York State General Municipal Law, as amended by the Laws of 1966.

1. By submission of this bid, each bidder and each person signing on behalf of any bidder certifies, and in the case of a joint bid each party thereto certifies as to its own organization, under penalty of perjury, that to the best of his knowledge and belief:
  - a. The prices in this bid have been arrived at independently without collusion, consultation, communication, or agreement, for the purpose of restricting competition, as to any matter relating to such prices with any other bidder or with any competitor; and
  - b. Unless otherwise required by law, the prices which have been quoted in this bid have not been knowingly disclosed by the bidder and will not knowingly be disclosed by the bidder prior to the opening, directly or indirectly, to any other bidder or to any competitor; and
  - c. No attempt has been made or will be made by the bidder to induce any other person, partnership or corporation to submit or not to submit a bid for the purpose of restricting competition.
  
2. A bid shall not be considered for award nor shall any award be made where Sections 1, (a), (b), and (c) above have not been complied with, provided, however, that if in any case the bidder cannot make the foregoing certification, the bidder shall so state and shall furnish with the bid a signed statement that sets forth in detail the reasons therefore. Where Sections 1 (a), (b), and (c) above have not been complied with, the bid shall not be considered for award nor shall any award be made unless the head of the purchasing unit of the Town of Greenburgh thereof to which the bid is made, or his designee, determines that such disclosure was not made for the purpose of restricting competition.

Dated: \_\_\_\_\_, 2016

(Seal of Corporation)

\_\_\_\_\_  
Legal Name of Person, Firm or Corporation

\_\_\_\_\_  
Street

\_\_\_\_\_  
City, State, Zip

Signed \_\_\_\_\_ Title \_\_\_\_\_

(\_\_\_\_) \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_

Phone \_\_\_\_\_ Fax \_\_\_\_\_

\_\_\_\_\_  
Email: