



**TOWN OF GREENBURGH  
BUILDING DEPARTMENT**

177 HILLSIDE AVENUE, GREENBURGH, NEW YORK 10607

(914) 993 - 1562

Fax (914) 993 - 1570

[www.GreenburghNY.com](http://www.GreenburghNY.com)

email: [building@greenburghny.com](mailto:building@greenburghny.com)

**Fee: \$100**

**APPLICATION # \_\_\_\_\_ - \_\_\_\_\_**

**OPERATING PERMIT FOR MOBILE FOOD PREPARATION VEHICLES**

An Annual Operating Permit is required for any mobile food preparation vehicle

**For Office Use Only**

Inspector Assigned: \_\_\_\_\_

Approved By: \_\_\_\_\_

**SUBJECT PROPERTY INFORMATION**

Street Address \_\_\_\_\_ City \_\_\_\_\_ Zip \_\_\_\_\_

Parcel ID \_\_\_\_\_

**OWNER/LESSEE INFORMATION**

Property Owner \_\_\_\_\_ Phone # \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

E-Mail: \_\_\_\_\_

Food Truck Owner \_\_\_\_\_ Phone # \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

E-Mail: \_\_\_\_\_

**APPLICANT INFORMATION**

Name \_\_\_\_\_ Phone # \_\_\_\_\_

Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

E-Mail: \_\_\_\_\_

I hereby certify that I am authorized to make this application and that I am in compliance with maintenance requirements of Section 319.10 (attached)

Signature \_\_\_\_\_ Date \_\_\_\_\_

## **New York State Fire Code 319.10**

319.10 Maintenance. Maintenance of systems on mobile food preparation vehicles shall be in accordance with Sections 319.10.1 through 319.10.3.

319.10.1 Exhaust system. The exhaust system, including hood, grease-removal devices, fans, ducts and other appurtenances, shall be inspected and cleaned in accordance with Section 607.3.

319.10.2 Fire protection systems and devices. Fire protection systems and devices shall be maintained in accordance with Section 901.6.

319.10.3 Fuel gas systems. LP-gas containers installed on the vehicle and fuel-gas piping systems shall be inspected annually by an approved inspection agency or a company that is registered with the U.S. Department of Transportation to requalify LP-gas cylinders, to ensure that system components are free from damage, suitable for the intended service and not subject to leaking. CNG containers shall be inspected every 3 years in a qualified service facility. CNG containers shall not be used past their expiration date as listed on the manufacturer's container label.

Upon satisfactory inspection, the approved inspection agency shall affix a tag on the fuel gas system or within the vehicle indicating the name of the inspection agency and the date of satisfactory inspection.